Cool Air Flow

Warm Air Flow

Medium pressure supply duct

Provide minimum straight inlet duct equal to 1.5 times the units inlet diameter and the nearest elbow or as recommended by the unit manufacturer for the most stringent requirement

Duct Insulation

Removable Air Flow Sensor

DUAL

DUCT

TERMINAL

UNIT

Control Enclosure for DDC Controls by Manufacturer Typical of Two (2). Control Boxes must be accessible. See Floor Plans for locations

Low pressure supply duct to diffusers. See Floor Plans for location and size

Air Flow

To TEC By ATC

Temperature Sensor By ATC Manufacturer.

Detail : Dual Duct Terminal Unit - Ductwork

No Scale